

**Copy of the Water, Health and Sanitation Certificate issued by DYHO  
West Zone AMC**



અમદાવાદ મ્યુનિસિપલ કોર્પોરેશન  
મહાનગર સેવા સદન, હેલ્થ પશ્ચિમ ઝોન  
ડૉ. રમણભાઈ પટેલ ભવન, ઉસ્માનપુરા ચાર રસ્તા, અમદાવાદ

75  
સ.પ.સ. ૭૫

SAFE DRINKING WATER AND SANITARY CONDITION

હેલ્થ પશ્ચિમ ઝોન
ઇન્ડાઇડ નં. 871
ઇન્ડાઇડ તા. 12/6/25
આઉટાઇડ તા. 16/6/25

**CERTIFICATE**



CERTIFICATE NO:- 02

Date : 11.06.2025

IT IS CERTIFIED THAT AN INSPECTION TEAM HEAD BY DR. MEHUL ACHARYA DYHO WEST ZONE FROM AHMEDABAD CORPORATION INSPECTED DOON BLOSSOM ACADEMY NEW C.G. ROAD, CHANDKHEDA, AHMEDABAD 382424. ON DT. 26.05.2025 AND WATER SAMPLE TAKEN BY CENTRAL LABORATORY OF AMC FOUND FIT SO THAT DOON BLOSSOM ACADEMY HAS SAFE DRINKING WATER FACILITIES FOR THE STUDENT AND MEMBERS OF STAFF OF INSTITUTION AND IS MAINTAINING THE HYGIENIC SANITATION CONDITIONS IN THE SCHOOL BUILDING & THE AMPUS AS PER THE NORMS PRESCRIBED BY THE CENTRAL/STATE /U.T. Govt.

THIS CERTIFICATE VALID FOR A PERIOD OF ONE YEAR.( DT.26.05.2025 TO 25.05.2026)

SIGNATURE WITH SEAL :   
DY. H.O. (W.Z.)

NAME : DR. MEHUL ACHARYA

DESIGNATION : DYHO WEST ZONE AMC

TO ,

DOON BLOSSOM ACADEMY,

NEW C.G. ROAD,

CHANDKHEDA ,

DOON BLOSSOM ACADEMY  
NEW C.G. ROAD, CHANDKHEDA.

  
PRINCIPAL


AVADH CHARITABLE TRUST

  
TRUSTEE

# Copy of the Water Examination Report issued by Central Laboratory, Ahmedabad



**AHMEDABAD MUNICIPAL CORPORATION**  
**MAHANAGAR SEVA SADAN**  
**CENTRAL LABORATORY**  
(An ISO 9001: 2015 Accredited Laboratory)



Dudheshwar Water Works Compound, Dudheshwar, Ahmedabad-380 004, Gujarat, India  
E-mail: centrallab@ahmedabadcity.gov.in, Phone No-(079) 25631105, 25630438.

May 26, 2025.

To,  
The Manager,  
Doon Blossom Academy,  
Near Chanakya Plaza, New C.G. Road,  
Chandkheda, Ahmedabad.

Dear Sir,

We have analyzed your water samples collected on Dt. 15-05-2025 for the following **Chemical and Bacteriological** parameters. The analysis report is as hereunder.

Sr. No.	Parameter	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	Sample Value
		As per IS-10500-2012		
A.	Organoleptic and Physical Parameters			
1	Colour, Hazen units, Max	5	15	0.1
2	pH value	6.5-8.5	No relaxation	7.7
3	Turbidity, NTU, Max	1	5	0.31
4	Total dissolved solids, mg/l, Max	500	2000	104
B.	General Parameters			
1	Total hardness (as CaCO <sub>3</sub> ), mg/l, Max	200	600	20
2	Calcium (as Ca), mg/l, Max	75	200	4
3	Magnesium (as Mg), mg/l, Max	30	100	2.44
4	Chloride (as Cl), mg/l, Max	250	1000	25
5	Sulphate (as SO <sub>4</sub> ) mg/l, Max	200	400	6.2
6	Total alkalinity (as CaCO <sub>3</sub> ), mg/l, Max	200	600	40
7	Free residual chlorine, mg/l, Min	0.2	1.0	Nil
C.	Bacteriological Quality of Drinking Water			
1	Total Coliform bacteria, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable
2	E. coli, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable
<b>Remarks:</b>				
1. The Central Laboratory, AMC, has collected the samples.				
2. The result contained in this report relate only to the sample material tested.				
3. The report is not being reproduce wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.				
NOTE — It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still 'permissible limit in the absence of alternate source' in column 4, above which the sources will have to be rejected. May be tolerated in the absence of an alternative source but up to the limits indicated.				

**Dr. Hiren C. Mandalia**  
Scientist In-Charge

**DOON BLOSSOM ACADEMY**  
**NEW C.G. ROAD, CHANDKHEDA.**

**PRINCIPAL**

**AVADH CHARITABLE TRUST**

**TRUSTEE**